Oven Run B Passive Treatment System

April 16, 2025

Presented by: Tim Danehy, BioMost, Inc. Contributors:

Cliff Denholm, IV, Stream Restoration Incorporated Cody "Buck" Neely, PE, Dan Guy, PG, BioMost, Inc.

2025 West Virginia Mine Drainage Task Force Symposium, Charleston, WV

Oven Run B – Stoystown, PA



Why am I Talking?

• Never to criticize, but to think critically.

- Share experience and observations.
- Hope other can learn from us.
- Get feedback to do our work better.

Very appreciative to PADEP, Bureau of Abandoned Mine Reclamation for all their work and willingness to work with us.



Oven Run B Passive System

Information available on Datashed: datashed.org/project-oven-run-site-b
Water monitoring data from 1999 onward.

Design plans, O&M plan, as-built, water monitoring, reports, schematic, etc.

• Original system designed in 1998 and constructed in 1999.

Construction Cost: \$1,101,948

Worked Well first Two Years
Performance declined
Even with poor quality effluent, significant partial treatment was maintained



Oven Run B System Background

- 1999-2010 monitored quarterly
- 1999-2008 flushed 2-3x/yr
- July 2001 distribution pipe added to SAP1
- October 2001 removed iron & added compost
- Nov. 2006 fixed Pond 3 HDPE liner
- June 2007 fix Pond 3 water level structure
- March 2008 System Evaluation by BAMR
- 2013-2017 System monitored and assessed



- December 2017 Evaluation by Stream Restoration Incorporated (SRI)
- July 2018 Stonycreek Conemaugh River Improvement & BAMR request SRI to develop rehabilitation treatment options and cost estimates

Original (1999) System Performance (Pre-Rehab)



2018 Site Investigation

• SRI, BioMost, St. Francis Univ. BAMR, SCRIP, PACD, SCC, SCCD



2018 Sampling & Evaluation

• St. Francis Water Sampling & Ferric / Ferrous Evaluation

	STARTING	ADIUSTED	FILTERED	FILTERED	FILTERED
Sample location	FIELD pH	pH	IRON	MANG	ALUM
			15.30	6.23	12.31
OPPI	2.5	3.5	2.12	6.43	11.60
ORBI		4.0	<0.10	5.79	0.73
		5.0	<0.10	5.85	0.54
			14.78	5.94	11.74
ORBSAP1	2.5	3.4	0.29	5.92	3.86
Overflow	2.5	4.0	<0.10	<0.05	1.28
		5.9	<0.10	0.15	1.06

St. Francis Ferric Test 9/27/18 9/27/18 SFU Sample Data on datashed.org

Titration Test Data

SAP1 2/12/20 (BioMost)

Observation: Almost no Iron on Top of SAP 1 Compost

2019 Test Pits

• SRI, BioMost, St. Francis Univ.





2019 Limestone Analysis

• 92% Calcium Carbonate (CaCO3) avg 99% CaCO3 Equivalent avg.

> BIOMOST ST. FRANCIS UNI

05/08/19

CLIENT 05/08/19

05/21/19

STRONG

87.50

12.35

99.92

TOTAL ANALY

- 56

**

16

151413

BIOMOST, INC. 434 SPRING ST. EXT

MARS, PA 16046

SAMPLE MARKED

DATE SAMPLED:

SAMPLE RECEIVED

SAMPLE REPORTED

INTENSITY OF FIZZ

Approved by:

CALCIUM CARBONATE

MAGNESIUM CARBONATE

CALCIUM CARBONATE EQUIVALENT

PROCEDURE FOLLOWED: ASTM C 1271 (Modified)

SAMPLED BY

BIOMOST, INC.

MARS, PA 16046

SAMPLE MARKED

DATE SAMPLED:

SAMPLE RECEIVED

SAMPLE REPORTED

INTENSITY OF FIZZ

SAMPLED BY

BIOMOST, INC. PA DEP Lab# 33-00325 434 SPRING ST. EXT. MARS, PA 16046 SAMPLE MARKED BIOMOST ST. FRANCIS UNIVERSITY 151414 434 SPRING ST. EXT. DATE SAMPLED: 05/08/19 SAMPLED BY CLIENT SAMPLE RECEIVED 05/08/19 SAMPLE REPORTED 05/21/19 BIOMOST ST. FRANCIS U 151412 PROCEDURE FOLLOWED: ASTM C 1271 (Modified) 05/08/19 CLIENT 05/08/19 TOTAL ANALYSIS (Dry) 05/21/19 INTENSITY OF FIZZ STRONG CALCIUM CARBONATE 95.12 MAGNESIUM CARBONATE 2.56 16 PROCEDURE FOLLOWED: ASTM C 1271 (Modified) 16 CALCIUM CARBONATE EQUIVALENT 98.33 TOTAL ANA Date: 05/21/19 Michael J. Cheetnut, Water Lab Director STRONG CALCIUM CARBONATE 91.99 MAGNESIUM CARBONATE 6.42 CALCIUM CARBONATE EQUIVALENT 00.05 Date: 05/21/19 Michael J. Chestnut, Water Lab Director

Date: 05/21/19 Michael J. Chestnut, Water Lab Director

Analysis by G&C Coal Analysis Lab.

2019 Bucket Tests
• St. Francis University
BioMost/SRI procedure

- Raw AMD
- Limestone from Test PitsWashed prior to test
- 7-hr alkalinity ~125 mg/I
 18-hr alkalinity ~135 mg/

Date	Time	Date + Time	Time elapsed	Bucket	pН	SPC	Alkalinity	Fe
4/8/2019	14:16	4/8/2019 14:16	0:00	1	2.77		11.4	33.3
4/8/2019	14:30	4/8/2019 14:30	0:14	1	4.93	1091	5	0
4/8/2019	15:00	4/8/2019 15:00	0:44	1	4.78	915	15	0.7
4/8/2019	15:30	4/8/2019 15:30	1:14	1	5.51	1052	35	
4/8/2019	16:00	4/8/2019 16:00	1:44	1	5.72	1109	51	3
4/8/2019	17:00	4/8/2019 17:00	2:44	1	5.94	1074	77	
4/8/2019	21:00	4/8/2019 21:00	6:44	1	6.38	1227	127	
4/9/2019	8:00	4/9/2019 8:00	17:44	1	6.71	1203	135	1
4/8/2019	14:16	4/8/2019 14:16	0:00	2	2.77			33.3
4/8/2019	14:30	4/8/2019 14:30	0:14	2	6.01	992	53	0
4/8/2019	15:00	4/8/2019 15:00	0:44	2	5.18	1020	27	0
4/8/2019	15:30	4/8/2019 15:30	1:14	2	5.58	1050	49	
4/8/2019	16:00	4/8/2019 16:00	1:44	2	5.79	1119	58	
4/8/2019	17:00	4/8/2019 17:00	2:44	2	6.15	1165	76	
4/8/2019	21:00	4/8/2019 21:00	6:44	2	6.52	569.1	126	
4/9/2019	8:00	4/9/2019 8:00	17:44	2	6.67	1255	138	0
4/8/2019	14:16	4/8/2019 14:16	0:00	3	2.77			33.3
4/8/2019	14:30	4/8/2019 14:30	0:14	3	5.53	1025	12	0
4/8/2019	15:00	4/8/2019 15:00	0:44	3	4.49	937	6	0
4/8/2019	15:30	4/8/2019 15:30	1:14	3	4.1	1038	11	
4/8/2019	16:00	4/8/2019 16:00	1:44	3	5.48	1083	27	
4/8/2019	17:00	4/8/2019 17:00	2:44	3	5.94	1188	57	
4/8/2019	21:00	4/8/2019 21:00	6:44	3	6.49	564.7	115	
4/9/2019	8:00	4/9/2019 8:00	17:44	3	6.55	1254	124	0

Data Review – Design Basis

- 1999 through 2018
- 103 Samples of Raw Water
- 37 Flow Measurements
 - Only 37 load measurements
- Design Basis
 - Average water quality from last 8 years Max design flow from all data (367 gpm)



IEASUR

E



Come On: Measure the Flow

I mean, come on, what can you really do with confidence, without accurate flow information?

- Tiff Hilton (The Elder), 1999

Tiff Hilton et al., 1999. "Did you Call me a SAPS!". *In Proceedings:* West Virginia Mine Drainage Task Force Symposium, Morgantown, WV . April 13-14, 1999. https://wvmdtaskforce.com/wp-content/uploads/2016/01/99-hilton.pdf

2019 Design Options & Cost Report

- Design Options and Cost Estimates developed by BioMost
- Passive & Active Options Considered
- Target Effluent Quality:
 - pH 6 8
 - Negative Acidity
 - Fe & Al < 1 mg/L (Mn not targeted)

Influent Water Characteristics

Sample ID	Flow (gpm) [Avg/Design/Max]	Avg Acidity (mg/L)	Avg Diss. Fe (mg/L)	Avg Diss. Al (mg/L)	Avg Diss. Mn (mg/L)	Avg Acid Load (lb/day)	Avg Diss. Fe Load (lb/day)	Avg Diss. Al Load (Ib/day)	Avg Diss. Mn Load (Ib/day)
ORBI	161/200/367	320	23.1	25.2	10.5	533	37	42	18

2019 Design Options & Cost Report

- Considered reuse and purchase new limestone
- Four different passive configurations
- One active configuration
- 20-Year Cost not adjusted for inflation (2019 dollars)

Type of Treatment	Construction Cost (Estimate)	Annual Cost (Estimate)	20-Yr Cost (Estimate)
Passive Treatment System Rehab (existing stone) - 5 AFVFPs	\$1,300,000	\$10,000	\$1,500,000
Passive Treatment System Rehab (existing stone) – 3 AFVFPS + 2 JVFPs	\$1,500,000	\$10,000	\$1,700,000
Passive Treatment System Rehab (new stone) 5 AFVFPS	\$1,800,000	\$10,000	\$2,000,000
Passive Treatment System Rehab (new stone) 3 AFVFPS + 2 JVFPs	\$2,000,000	\$10,000	\$2,200,000
Active Treatment System	\$1,200,000	\$65,000	\$2,500,000

Full report on Datashed

2019 Design Recommendation

Rehab passive system Three 3,000-ton AFVFPs Two 2,800-ton JVFPs • Reuse ~20,000 t limestone Use new "BOLTS" approach Modified (not full fill) Using Agri Drain Smart Drain Include sludge pond • Utilize existing footprint



THREE IN

1998 Design Schematic (Starting Point)



PADEP, BAMR 2008 Evaluation

1998 Design – SAP 1 Potential Issues



1998 Design – SAP 1 Potential Issues



Gwin, Dobson and Foreman, Inc. Altoona, PA. May 1998. Full design available on Datashed.

1998 Design – SAP 1 (Two Acres & 10,000 Tons)



PADEP, BAMR 2008 (Full Report on Datashed)



AutoFlushers – Use HDPE Pipe!

TEE

HDPE PIPE

FERNCOS

Don't Break Pipe Washing Stone

HDPE AFTER NINE ANNUAL WASHES



General Design Basis and Sizing Information



Batch Operated Limestone

Treatment System

BOLTS Information:

https://meridian.allenpress.com/reclamationsciences/article/doi/10.21000/RCSC-202300003/501488/Batch-Operating-Limestone-Treatment-Systems-BOLTS

AFVFP & BOLTS Performance Information:

https://www.asrs.us/wp-content/uploads/2024/08/Neely_301E.pdf



https://wvmdtaskforce.com/wp-content/uploads/2022/10/2022-13-danehy-et-al-2022-wv-10-year-passive-treatment-system-performance-evaluation.pdf

1 M	And I have a first the second	A A A A A A A A A A A A A A A A A A A	Statistical care of P. Scol. For Weiters and Scole Computer and Advances for 2007 Model and provide information computer and advances of both 2017 Computer Ph. 2019 Mar. Job Print, Computer Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of the Advances of t	-ALCONORN-		
		mattern and	2. The stand in our boots had a referring the Contract an available 2. The stand in our boots and an available of a california of a california contracted and differ parameters? "Available or annuality along the replace and other bolling. From 1 and annual and a california of a california of a california of the bolling from 1 and annual standard and an available of the parameters and a california of the standard and an available of the bolling from 1 and the bolling from 1 and the bolling from 1 and 1 a	Martin Montert	SHEET 1 of 3 System Dougs / Plan View LOCATION WAY, LIGENSIA NOTES	
REALITION A			laansalan 1. Been onemerinan had nateri yara bud'uh JUB 17 haapate may kualaan teasan an Afrikaan 4. Al teasan oo haar shara daarka taka II. Afrikaa adjaalaa ay 10.		OVEN RUN B PASSIVE TREATMENT SYSTEM	

System Schematic – With Telemetry





Search for: Registers

ters Alarms

ONE WEEK AT UPTO 4X Flow & Effluent pH (Spring 2024) **MAX DESIGN** 1600 8.00 1200 7.50 hЧ 800 7.00 Max Design Flow 367 400 6.50 A MAR gpm

Mdf

Effluent pH Flow Rate 6.00

Beyond O&M – We can Science!

American Society of Reclamation Sciences

- October 2024 Telemetry Webinar (www.asrs.us/events/webinars) Dan Guy, PG
- Use of Telemetry at a Passive Treatment System to Monitor Flow, pH, and Water Level
 - 2024 Knoxville: https://www.asrs.us/wp-content/uploads/2024/08/Guy_301A.pdf Dan Guy, PG
- Fill Type & Hold Time Impacts to Limestone-Only Automatic Vertical Flow Ponds
 - 2024 Knoxville: https://www.asrs.us/wp-content/uploads/2024/08/Neely_301E.pdf Buck Neely, PE

Scientific Advancements

• Void space of seasoned / washed / reused limestone: ~25%

- www.asrs.us/wp-content/uploads/2024/08/Guy_301A.pdf
- See also:
 - Reclamation Sciences "Batch Operating Limestone Treatment System (BOLTS): Greater Efficiency and Cost Savings". https://doi.org/10.21000/RCSC-202300003
- Established Passive References use 49% void.
 - www.asrs.us/wp-content/uploads/2021/09/0262-Watzlaf.pdf (49%)
- See also:
 - www.asrs.us/wp-content/uploads/2024/08/Danehy_301E.pdf

Can use the same volume of limestone multiple times per day.

- Potentially a game changer Double or triple treatment capacity.
 - Need to evaluate if additional complexity is worth it.
 - Possible inexpensive retrofit to existing systems.

Utilizing Flume Ultrasonic and BOLTS Radar Monitoring to Perform Void Space Analysis





BOLTS System Reconfiguration



Turned off all three fill valves, added stop logs to AFVFP1 and AFVFP2 fill valves to force all water into AFVP3. Monitored how long it took to fill AFVP3 and flow measured at flume.

Hold Time Analysis

- Full Scale Science on a Seasoned Passive System
- Experimental setups
 - #1: 24-hr gradual fill / 12-hour average hold
 - #2: Rapid fill / 12-hr hold
 - #3: Rapid fill / 9-hr hold
 - #4: Rapid fill / 6-hr hold
- Each testing condition was allowed to run for 2 weeks prior to sampling (Nov 2023 – Jan 2024)
 - No instances of overflow were observed (telemetry)
 - Compare acid load reductions in SP1 effluent

(#1) 24- HR Gradual Fill (12-Hr Avg Hold) Rapid Drain initiates 24-hr apart ~1-hr to drain (11.5-hr avg retention) 24-hr cycle 23-hr fill & 1-hr drain



(#2) Rapid Fill (12-Hr Hold)

True Hold Times

- 14-hr cycle
- 1-hr fill & 1-hr drain



ID	рН	Flow (gpm)	Cond (µmhos/cm)	D. Al (mg/L)	D. Fe (mg/L)	D. Mn (mg/L)	ACID (mg/L)	ACID LOAD (lb/d)
SP1 out	4.63	87.2	1220	7.9	0.2	3.5	61	64

(#3) Rapid Fill (9-Hr Hold)

True Hold Times
11-hr cycle
1-hr fill & 1-hr drain



ID	pН	Flow (gpm)	Cond (µmhos/cm)	D. Al (mg/L)	D. Fe (mg/L)	D. Mn (mg/L)	ACID (mg/L)	ACID LOAD (lb/d)
SP1 out	4.29	112.4	1240	12.7	0.5	4.5	84	114

(#4) Rapid Fill (6-Hr Hold)

• True Hold Times

- 8-hr cycle
- 1-hr fill and 1-hr drain



Acid Load Summary



SP1 (Lab) Acid Loads

ACID LOAD REMOVED

Acid Load Constituents



💭 Calc Acid 📕 Proton 📕 Fe 📃 Al 📕 Mn

How Can We Use It?



• <u>Triple</u> Acid Load Neutralization Potential

Design

More efficiently use smaller quantities of limestone

• \$ or space limited projects

How small can you make these ponds?

A lot depends on flow

2022 As-Built Drawing

DOCUMENT WHAT THE SYSTEM WAS DESIGNED TO DO

O&M Plan and As-Built available on Datashed

Design Basis Included on As-Built

 REPRESENTATIVE RAW WATER QUALITY

 pH
 Acid
 T Fe
 T Mn
 T Al
 Sulfates

 AVERAGE
 2.80
 320
 28
 11
 25
 799

NOTE: COMPONENTS TO DESIGNED TO REMOVE MANGANESE NOT INCLUDED.

If the System is Flowing at 1,500 GPM with 3,000 Ib/day influent acid load, should we expect 6+ pH effluent?

> Probably Not. Let's be Reasonable

Pre- and Post- Construction Monitoring and O&M Plan with As-Built available on Datashed

Does it Work? Sample 4/8/24 (after ~1.5 years)

ID	рН	Flow (gpm)	Sulfate (mg/L)	T. Al (mg/L)	T. Fe (mg/L)	T. Mn (mg/L)	ACID (mg/L)	ACID LOAD (lb/d)
Influent (ORBI)	2.9	848	558	16.5	12.7	6.8	216	2202
Effluent (ORBO)	6.6	848+	425	1.0	0.3	3.0	-65	-662

Total Acid Load (2467 lb/day acid is design): 2864

Max Design Flow

>4X DESIGN FLOW

How Does it Work? April 2024 (after ~1.5 years)

Acid Load Removal by Constituent

April 8, 2024 (848 gpm) 1.5 Years

Pollutant Concentration

April 8, 2024 (848 gpm)

How Does it Work Now? January 1 – April 15, 2025 (~2.5 years)

Biology is Cool – Holding Pond 8/2/22

Biology is Cool – SP3 pH Probe 7/7/22

Thank You

Acknowledgements PA DEP BAMR Foundation for Pennsylvania Watersheds Stream Restoration Incorporated BioMost, Inc. Earth Shapers, LLC Saint Francis University Landowners

